

RESOLUTION NO. 02-14-2013- 02 (SUMMIT RIDGE PHASE III)

A RESOLUTION OF THE COLLIER TOWNSHIP MUNICIPAL AUTHORITY AGREEING TO ACCEPT OWNERSHIP OF CERTAIN SANITARY SEWERS AND MANHOLES AS INSTALLED AND CONSTRUCTED IN AND THROUGH SUMMIT RIDGE PHASE III

WHEREAS, the property developer, A. R. Building Co. has caused to be constructed, certain sanitary sewers, manholes and associated main line components in and through Summit Ridge Phase III; and,

WHEREAS, A. R. Building Co. has awarded the necessary contracts for the construction and installation of the system by and through T. A. Ward Constructors and,

WHEREAS, field observations of construction of the additional sanitary sewer lines were performed by NIRA Consulting Engineers, Inc. on behalf of the Collier Township Municipal Authority; and

WHEREAS, NIRA Consulting Engineers, Inc., by letter of January 28 2013, advised the Collier Township Municipal Authority that final inspection and testing of the sanitary sewer lines within Summit Ridge Phase III are complete; and,

WHEREAS, the sanitary sewer lines and manholes passed the required air and vacuum tests and passed the necessary deflection (mandrel) test; and,

WHEREAS, NIRA Consulting Engineers, Inc. recommended that the sewer lines listed in the attached exhibit sheets be accepted by the Collier Township Municipal Authority; and,

WHEREAS, A. R. Building Co. now has provided to the Collier Township Municipal

Authority its certification as to the construction cost of the said lines which were constructed at a construction cost of \$65,530.00, and;

WHEREAS A. R. Building Co. has arranged to post with the Collier Township Municipal Authority a Letter of Credit, in the amount of fifteen (15%) percent of the construction costs and said bond is for a period of eighteen months from the date of the completion and acceptance of the work and is in the amount of \$9,979.50.

NOW THEREFORE, the Collier Township Municipal Authority at a publicly held meeting on the 14th day of February, 2013.


1. Reviewed this Resolution, and formerly adopted the Resolution, accepting ownership and control of the sanitary sewer lines and manholes listed in the attached exhibit as of the date of this Resolution now that A. R. Building Co. has supplied a letter of credit , bill of sale and has and completed the unfinished items set forth in the letter of December 13, 2012 from the consulting engineer.
2. The lines and manholes hereby accepted are in and through the Summit Ridge Phase III with the said system comprising of approximately 979 linear feet of 8" PVC pipe and eight (8) manholes located in Summit Ridge Phase III as an Authority sanitary sewer system now and into the future.
3. This Resolution of acceptance of the public improvement shall be maintained as part of the records of the Collier Township Municipal Authority and a copy shall be delivered to A. R. Building Co. or their agents that have agreed to the issuance and delivery of said letter of credit as required above, to the Collier Township Municipal Authority.

Adopted this 14th day of February, 2013, by a majority vote of the members of the Collier Township Municipal Authority.

COLLIER TOWNSHIP MUNICIPAL AUTHORITY



Daniel Oberleitner, Chairman



Dan Fotovich, Secretary

Collier Township Municipal Authority
Summit Ridge PRD Sanitary Sewers – Phase 3
NIRA File No. 6-118-76

<u>MH to MH</u>	<u>Pipe/Size Composition</u>	<u>Air Test</u>	<u>Mandrel Test</u>	<u>Vacuum Test</u>	<u>C-C Footage</u>
Ex. 63* - 63A*	8" PVC	10/16/12	10/16/12	10/16/12	90
Ex. 63 - 63B*	8" PVC	10/16/12	10/16/12	10/16/12	98
63B – 63C*	8" PVC	10/16/12	10/16/12	10/16/12	144
63C – 63D*	8" PVC	10/16/12	10/16/12	10/16/12	96
63D – 63 E*	8" PVC	10/16/12, 10/22/12	10/16/12	10/16/12	60
63E – 63 F*	8" PVC	10/16/12	10/16/12	10/16/12	273
63F – 63G*	8" PVC	10/16/12	10/16/12	10/16/12	218

*Indicates manhole vacuum tested.

Total C-C L.F. of 8" PVC Pipe. 979

Total Number of Manholes. 8 EA.