

**RESOLUTION NO. 02-14-2013- 03**

**(BALDWIN SEWER EXTENSION AT  
CENTENNIAL POINTE PUMP STATION)**

A RESOLUTION OF THE COLLIER TOWNSHIP MUNICIPAL AUTHORITY AGREEING  
TO ACCEPT OWNERSHIP OF CERTAIN SANITARY SEWERS AND MANHOLES AS  
INSTALLED AND CONSTRUCTED AND IDENTIFIED AS THE BALDWIN SEWER  
EXTENSION AT CENTENNIAL POINT PUMP STATION

WHEREAS, the Collier Township Municipal Authority as developer. has caused to be constructed, certain sanitary sewers line extension for to provide sewer service in the future to certain areas of Collier Township that would be serviced off of the Centennial Pointe Pump Station; and,

WHEREAS, the Collier Township Municipal Authority had Gay Mancini Construction install one manhole and approximately 79 feet of this line and in November of 2010 Independent Enterprises extended the line approximately additional 25 feet to a manhole in Baldwin Road so as to provide for future use; and,

WHEREAS, field observations of construction of the additional sanitary sewer lines were performed by NIRA Consulting Engineers, Inc. on behalf of the Collier Township Municipal Authority; and

WHEREAS, NIRA Consulting Engineers, Inc., by letter of January 31 2013, advised the Collier Township Municipal Authority that final inspection and testing of the sanitary sewer line extension is complete; and,

WHEREAS, the sanitary sewer lines and manholes passed the required air and vacuum tests

and passed the necessary deflection (mandrel) test; and,

WHEREAS, NIRA Consulting Engineers, Inc. recommended that the sewer lines listed in the attached exhibit sheets be accepted by the Collier Township Municipal Authority; and,

WHEREAS, the said lines were installed at a cost to CTMA in the amount of \$5,068.60 for said construction, and;

WHEREAS said lines were constructed by CTMA for CTMA future use, no bonds are necessary or required.

NOW THEREFORE, the Collier Township Municipal Authority at a publicly held meeting on the 14<sup>th</sup> day of February, 2013.


1. Reviewed this Resolution, and formerly adopted the Resolution, accepting ownership and control of the sanitary sewer lines and manholes listed in the attached exhibit as of the date of this Resolution.
2. The lines and manholes hereby accepted comprising of approximately 79 linear feet of 8" PVC pipe and one (1) manhole for use in the future.
3. This Resolution of acceptance of the public improvement shall be maintained as part of the records of the Collier Township Municipal Authority.

Adopted this 14<sup>th</sup> day of February, 2013, by a majority vote of the members of the Collier Township Municipal Authority.

COLLIER TOWNSHIP MUNICIPAL AUTHORITY



\_\_\_\_\_  
Daniel Oberleitner, Chairman



\_\_\_\_\_  
Dan Fotovich, Secretary

Collier Township Municipal Authority  
 Baldwin Sewer Extension at Centennial Pointe Pump Station  
 Gary Mancini Construction  
 NIRA File No. 6-97-76A (6-97-76-4)

<u>Manhole to Manhole</u>	<u>Pipe/Size Composition</u>	<u>Air Test</u>	<u>Mandrel Test</u>	<u>Vacuum Test</u>	<u>C-C Footage</u>
●Ex. #1 to SR-01 (SR-100)	8" PVC	12/27/07	12/27/07■ 01/25/13■		20Δ
SR-01 (SR-100) * to End of Pipe	8" PVC	12/26/07	01/25/13■	12/27/07	59'Δ
End of Pipe to SR-101*	8" PVC	11/04/10	01/25/13■	11/04/10	25'●●

\*Indicates Manhole Vacuum Tested.

●Centennial Pointe existing Manhole #1 Vacuum Tested 01/18/13.

●●Installed by Independent Enterprises, Inc. 25 L.F. of pipe accepted by Resolution 04-14-11-01.

■Mandrel Tested by Gary Mancini Construction.

ΔInstalled by Gary Mancini Construction.

Total C-C L.F. 8" PVC Pipe	79 L.F. Δ
Total Number of Manholes	1 EACH Δ

01/30/13